

Energy Performance Certificate



1 Mount Pleasant Cottage,
CORNHILL-ON-TWEED,
TD12 4TE

Dwelling type: Detached
Date of assessment: 07 December 2007
Date of certificate: 11 December 2007
Reference Number: 8613-6912-4349-0373-0006
Total floor area: 123 m²

This home's performance is rated in terms of the energy use per square metre of floor area, energy efficiency based on fuel costs and environmental impact based on carbon dioxide (CO₂) emissions.

Energy Efficiency Rating

	Current	Potential
<i>Very energy efficient - lower running costs</i>		
(92-100) A		
(81-91) B		
(69-80) C		
(55-68) D		
(39-54) E		53
(21-38) F	34	
(1-20) G		
<i>Not energy efficient - higher running costs</i>		
England & Wales	EU Directive 2002/91/EC	

Environmental Impact (CO₂) Rating

	Current	Potential
<i>Very environmentally friendly - lower CO₂ emissions</i>		
(92-100) A		
(81-91) B		
(69-80) C		
(55-68) D		
(39-54) E		42
(21-38) F	35	
(1-20) G		
<i>Not environmentally friendly - higher CO₂ emissions</i>		
England & Wales	EU Directive 2002/91/EC	

The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the fuel bills will be.

The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO₂) emissions. The higher the rating the less impact it has on the environment.

Estimated energy use, carbon dioxide (CO₂) emissions and fuel costs of this home

	Current	Potential
Energy use	498 kWh/m ² per year	414 kWh/m ² per year
Carbon dioxide emissions	9.2 tonnes per year	7.7 tonnes per year
Lighting	£112 per year	£56 per year
Heating	£812 per year	£654 per year
Hot water	£313 per year	£139 per year

Based on standardised assumptions about occupancy, heating patterns and geographical location, the above table provides an indication of how much it will cost to provide lighting, heating and hot water to this home. The fuel costs only take into account the cost of fuel and not any associated service, maintenance or safety inspection. This certificate has been provided for comparative purposes only and enables one home to be compared with another. Always check the date the certificate was issued, because fuel prices can increase over time and energy saving recommendations will evolve.

To see how this home can achieve its potential rating please see the recommended measures.



Certification mark

Remember to look for the energy saving recommended logo when buying energy-efficient products. It's a quick and easy way to identify the most energy-efficient products on the market.

For advice on how to take action and to find out about offers available to help make your home more energy efficient, call **0800 512 012** or visit www.energysavingtrust.org.uk/myhome

About this document

The Energy Performance Certificate for this dwelling was produced following an energy assessment undertaken by a qualified assessor, accredited by the RICS, to a scheme authorised by the Government. This certificate was produced using the RdSAP 2005 assessment methodology and has been produced under the Energy Performance of Buildings (Certificates and Inspections) (England and Wales) Regulations 2007. A copy of the certificate has been lodged on a national register.

Assessor's accreditation number: RICS200146
Assessor's name: Philip Wragg
Company name/trading name: Northern Energy Assessors
Address: Victoria House
Hampshire Court, Newcastle-upon-Tyne, NE4 7YL
Phone number: 01912463816
Fax number: 01912869238
E-mail address: philip.wragg@northernenergyassessors.co.uk
Related party disclosure: none

If you have a complaint or wish to confirm that the certificate is genuine

Details of the assessor and the relevant accreditation scheme are on the certificate. You can get contact details of the accreditation scheme from our website at <http://www.rics.org> together with details of their procedures for confirming authenticity of a certificate and for making a complaint.

About the building's performance ratings

The ratings on the certificate provide a measure of the building's overall energy efficiency and its environmental impact, calculated in accordance with a national methodology that takes into account factors such as insulation, heating and hot water systems, ventilation and fuels used. The average energy efficiency rating for a dwelling in England and Wales is band E (rating 46).

Not all buildings are used in the same way, so energy ratings use 'standard occupancy' assumptions which may be different from the specific way you use your building. Different methods of calculation are used for homes and for other buildings. Details can be found at www.communities.gov.uk/epbd.

Buildings that are more energy efficient use less energy, save money and help protect the environment. A building with a rating of 100 would cost almost nothing to heat and light and would cause almost no carbon emissions. The potential ratings in the certificate describe how close this building could get to 100 if all the cost effective recommended improvements were implemented.

About the impact of buildings on the environment

One of the biggest contributors to global warming is carbon dioxide. The way we use energy in buildings causes emissions of carbon. The energy we use for heating, lighting and power in homes produces over a quarter of the UK's carbon dioxide emissions and other buildings produce a further one-sixth.

The average household causes about 6 tonnes of carbon dioxide every year. Adopting the recommendations in this report can reduce emissions and protect the environment. You could reduce emissions even more by switching to renewable energy sources. In addition there are many simple every day measures that will save money, improve comfort and reduce the impact on the environment, such as:

- Check that your heating system thermostat is not set too high (in a home, 21°C in the living room is suggested) and use the timer to ensure you only heat the building when necessary.
- Make sure your hot water is not too hot - a cylinder thermostat need not normally be higher than 60°C.
- Turn off lights when not needed and do not leave appliances on standby. Remember not to leave chargers (e.g. for mobile phones) turned on when you are not using them.

Visit the Government's website at www.communities.gov.uk/epbd to:

- Find how to confirm the authenticity of an energy performance certificate
- Find how to make a complaint about a certificate or the assessor who produced it
- Learn more about the national register where this certificate has been lodged
- Learn more about energy efficiency and reducing energy consumption

Recommended measures to improve this home's energy performance

1 Mount Pleasant Cottage,
CORNHILL-ON-TWEED,
TD12 4TE

Date of certificate: 11 December 2007
Reference Number: 8613-6912-4349-0373-0006

Summary of this home's energy performance related features

The following is an assessment of the key individual elements that have an impact on this home's performance rating. Each element is assessed against the following scale: Very poor / Poor / Average / Good / Very good.

Element	Description	Current performance	
		Energy Efficiency	Environmental
Walls	Sandstone, with internal insulation	Good	Good
Roof	Pitched, 100mm loft insulation	Average	Average
Floor	Suspended, no insulation (assumed)	-	-
Windows	Fully double glazed	Good	Good
Main Heating	Electric storage heaters	Poor	Very Poor
Main Heating Controls	Manual charge control	Poor	Poor
Secondary Heating	Room heaters, electric	-	-
Water Heating	Electric immersion, off-peak, no cylinderstat	Very Poor	Very Poor
Lighting	No low energy lighting	Very Poor	Very Poor
Current energy efficiency rating		F 34	
Current environmental impact (CO2) rating		F 35	

Recommendations

The measures below are cost effective. The performance ratings after improvement listed below are cumulative, that is they assume the improvements have been installed in the order that they appear in the table.

Lower cost measures (up to £500)	Typical savings per year	Performance rating after improvements	
		Energy Efficiency	Environmental
1 Loft Insulation	£46	F 36	F 37
2 Hot Water Cylinder Insulation	£43	F 38	F 37
3 Low Energy Lights	£35	E 39	F 38
Sub-total	£124		
Higher cost measures (over £500)			
4 New or Replacement Storage Heaters	£264	E 53	E 42
Total	£388		
Current energy efficiency rating		E 53	
Current environmental impact (CO2) rating		E 42	

Further measures to achieve even higher standards

The further measures listed below should be considered in addition to those already specified if aiming for the highest possible standards for this home.

5 Solar Water Heating	£34	D 55	E 44
6 Photovoltaics	£57	D 57	E 47
Enhanced energy efficiency rating		D 57	
Enhanced environmental impact (CO2) rating		E 47	

Improvements to the energy efficiency and environmental impact ratings will usually be in step with each other. However, they can sometimes diverge because reduced energy costs are not always accompanied by a reduction in carbon dioxide (CO₂) emissions

About the cost effective measures to improve this home's performance ratings

Lower cost measures (typically up to £500 each)

These measures are relatively inexpensive to install and are worth tackling first. Some of them may be installed as DIY projects. DIY is not always straightforward, and sometimes there are health and safety risks, so take advice before carrying out DIY improvements.

1 Loft Insulation

Insulation laid in the loft space over the joists or between roof rafters to a depth of at least 250mm will significantly reduce heat loss through the roof. The insulation can be installed by professional contractors but also by a capable DIY enthusiast. Loose granules may be used instead of insulation quilt; this form of loft insulation can be blown into place and can be useful where access is difficult. Ensure that the loft space has adequate ventilation and seek advice about this if unsure.

2 Hot Water Cylinder Insulation

Increasing the thickness of existing insulation up to 160mm around the hot water cylinder will help to reduce fuel bills. The jacket should be fitted over the top of the existing insulation and over any thermostat clamped to the cylinder. Hot water pipes from the hot water cylinder should also be insulated, using pre-formed pipe insulation of 50mm thickness, for as far as they can be accessed. All these materials can be purchased from DIY stores and installed by a competent DIY enthusiast.

3 Low Energy Lights

Replacement of traditional light bulbs with energy saving recommended ones will reduce lighting costs over the lifetime of the bulb, and they last up to 12 times longer than ordinary light bulbs.

Higher cost measures (typically over £500 each)

4 New or Replacement Storage Heaters

Modern storage heaters are smaller and easier to control than the older type in the property. Ask for a quotation for new, fan-assisted heaters with automatic charge control. A dual-immersion cylinder which can be installed at the same time, will provide cheaper hot water than the system currently installed. As installations should be in accordance with the current regulations covering electrical wiring, only a qualified electrician should carry out the installation. Building regulations apply to this work, so your local authority building control department should be informed, unless the installer is registered with a competent persons scheme^{1}, and can therefore self-certify the work for Building Regulation Compliance.

About the further measures to achieve even higher standards

Further measures that could deliver even higher standards for this home.

5 Solar Water Heating

A thermal panel, usually fixed to the roof, uses the sun to pre-heat the hot water supply. This will significantly reduce the demand on the heating system to provide hot water and hence save fuel and money. The Solar Trade Association has up-to-date information on local installers and any grant that may be available.

6 Photovoltaics

A solar photovoltaic (PV) system is one which converts light directly into electricity via panels placed on the roof with no waste and no emissions. This electricity is used throughout the home in the same way as the electricity purchased from an energy supplier. The Solar Trade Association has up-to-date information on local installers and any grant that may be available. Building Regulations apply to this work, so your local authority building control department should be informed, unless the installer is registered with a competent persons scheme^{1}, and can therefore self-certify the work for Building Regulation compliance.

¹ For information on competent persons schemes enter "existing competent person schemes" into an internet search engine or contact your local Energy Saving Trust advice centre on 0800 512 012.