

Energy performance certificate (EPC)

27, Berrys Wood
NEWTON ABBOT
TQ12 1UP

Energy rating

E

Valid until: **2 September 2024**

Certificate number: **0978-4054-7281-2774-4904**

Property type **End-terrace house**

Total floor area **91 square metres**

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Energy rating and score

This property's energy rating is E. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60



Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Good
Roof	Pitched, 200 mm loft insulation	Good
Window	Fully double glazed	Average
Main heating	Electric storage heaters	Average
Main heating control	Manual charge control	Poor
Hot water	Electric immersion, off-peak	Average
Lighting	Low energy lighting in 44% of fixed outlets	Good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, electric	N/A

Primary energy use

The primary energy use for this property per year is 362 kilowatt hours per square metre (kWh/m²).

Additional information

Additional information about this property:

- Dwelling may be exposed to wind-driven rain
-

How this affects your energy bills

An average household would need to spend **£1,090 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £552 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2014** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 7,758 kWh per year for heating
- 2,885 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is E. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces 6 tonnes of CO₂

This property produces 5.8 tonnes of CO₂

This property's potential production 1.0 tonnes of CO₂

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Floor insulation	£800 - £1,200	£92
2. Increase hot water cylinder insulation	£15 - £30	£65
3. Low energy lighting	£50	£25
4. Gas condensing boiler	£3,000 - £7,000	£330
5. Solar water heating	£4,000 - £6,000	£41

Step	Typical installation cost	Typical yearly saving
6. Solar photovoltaic panels	£9,000 - £14,000	£271

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	James Le Gallez
Telephone	07863254599
Email	jim@legallez.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Northgate
Assessor's ID	NGIS802554
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	3 September 2014
Date of certificate	3 September 2014
Type of assessment	RdSAP
