

# Energy performance certificate (EPC)

Flat 1 889, Bristol Road Selly Oak BIRMINGHAM B29 6ND	Energy rating <b>D</b>	Valid until: <b>13 October 2029</b> Certificate number: <b>9608-7991-6270-5691-0940</b>
---	---------------------------	--

Property type **Ground-floor flat**

Total floor area **90 square metres**

## Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

## Energy efficiency rating for this property

This property's current energy rating is D. It has the potential to be C.

[See how to improve this property's energy performance.](#)


The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60



## Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Window	Single glazed	Very poor
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Roof	(another dwelling above)	N/A
Floor	Suspended, no insulation (assumed)	N/A
Secondary heating	None	N/A

## Primary energy use

The primary energy use for this property per year is 236 kilowatt hours per square metre (kWh/m<sup>2</sup>).

## Additional information

Additional information about this property:

- Cavity fill is recommended

---

## Environmental impact of this property

This property's current environmental impact rating is D. It has the potential to be C.

Properties are rated in a scale from A to G based on how much carbon dioxide (CO2) they produce.

Properties with an A rating produce less CO2 than G rated properties.

An average household produces 6 tonnes of CO2

This property produces

3.8 tonnes of CO2

This property's potential production

2.5 tonnes of CO2

By making the [recommended changes](#), you could reduce this property's CO2 emissions by 1.3 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

## How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from D (67) to C (76).

Recommendation	Typical installation cost	Typical yearly saving
1. Cavity wall insulation	£500 - £1,500	£108
2. Floor insulation (suspended floor)	£800 - £1,200	£69
3. Replace single glazed windows with low-E double glazed windows	£3,300 - £6,500	£57

## Paying for energy improvements

[Find energy grants and ways to save energy in your home. \(<https://www.gov.uk/improve-energy-efficiency>.\)](#)

## Estimated energy use and potential savings

Estimated yearly energy cost for this property	£819
Potential saving	£234

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice](#)

(<https://www.simpleenergyadvice.org.uk/>).

### Heating use in this property

Heating a property usually makes up the majority of energy costs.

### Estimated energy used to heat this property

Space heating	12281 kWh per year
Water heating	2188 kWh per year

### Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
Cavity wall insulation	2479 kWh per year

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### **Assessor contact details**

Assessor's name	Mark Hawthorne
Telephone	07793 140 000
Email	<a href="mailto:hawthorneconsultants@gmail.com">hawthorneconsultants@gmail.com</a>

### **Accreditation scheme contact details**

Accreditation scheme	Stroma Certification Ltd
Assessor ID	STRO014077
Telephone	0330 124 9660
Email	<a href="mailto:certification@stroma.com">certification@stroma.com</a>

### **Assessment details**

Assessor's declaration	No related party
Date of assessment	10 October 2019
Date of certificate	14 October 2019
Type of assessment	<a href="#">RdSAP</a>

---