Energy performance certificate (EPC)

Flat 4 20 High Street SHREWSBURY SY1 1SJ	Energy rating **E**	Valid until:	**10 March 2035**
		Certificate number:	**3835-0237-9400-0719-7292**

Property type	Top-floor flat
Total floor area	74 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's energy rating is E. It has the potential to be E.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Breakdown of property’s energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property’s age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Walls	Average thermal transmittance 0.26 W/m²K	Very good
Roof	Average thermal transmittance 0.12 W/m²K	Very good
Floor	Average thermal transmittance 0.17 W/m²K	Very good
Windows	Partial double glazing	Poor
Main heating	Air source heat pump, warm air, electric	Average
Main heating control	Programmer and room thermostat	Average
Hot water	Electric immersion, standard tariff	Very poor
Lighting	Excelent lighting efficiency	Very good
Secondary heating	None	N/A
Air tightness	(not tested)	N/A

Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO2. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

- Air source heat pump

Primary energy use

The primary energy use for this property per year is 123 kilowatt hours per square metre (kWh/m2).

Smart meters

This property had **a smart meter for electricity** when it was assessed.

Smart meters help you understand your energy use and how you could save money. They may help you access better energy deals.

Find out about using your smart meter (https://www.smartenergygb.org/using-your-smart-meter)

How this affects your energy bills

An average household would need to spend **£1,538 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £0 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2025** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment

This property's environmental impact rating is B. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household produces	6 tonnes of CO2
This property produces	0.9 tonnes of CO2
This property's potential production	0.9 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

The assessor did not make any recommendations for this property.

Advice on making energy saving improvements

Get detailed recommendations and cost estimates (www.gov.uk/improve-energy-efficiency)

Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

- Free energy saving improvements: Warm Homes Local Grant (www.gov.uk/apply-warm-homes-local-grant)
- Help from your energy supplier: Energy Company Obligation (www.gov.uk/energy-company-obligation)

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Sean Caddick
Telephone	0
Email	seancaddick@live.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/027441
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	11 March 2025
Date of certificate	11 March 2025
Type of assessment	SAP